

**Town of Sturbridge  
Joshua Hyde Public Library  
Sturbridge, MA**

**2017**

**HVAC Systems**

**Prepared For:**

**Town of Sturbridge  
306 Main Street  
Sturbridge, MA 01566**

**Prepared By:**

**BLW Engineers, Inc.  
311 Great Road, P.O. Box 1551  
Littleton, MA 01460**

**July 27, 2017**

## **Section 23 00 00 – Heating, Ventilating and Air Conditioning (HVAC)**

### ***GENERAL***

The current HVAC system for the existing 8,300 square foot Town Library consists of two rooftop packaged gas heating/electric cooling units, two through wall heat pump units, roof exhaust fans and local controls.

The building was renovated in 1988 including a new HVAC system including electric heat/cool rooftop units; in 2002 the rooftop units were replaced with new gas heating/electric cool rooftop units

### ***EXISTING CONDITIONS***

The building is provided with heated, ventilated by two rooftop packaged gas heating/electric cooling units, two through wall heat pump units, roof exhaust fans and

The following equipment provides heating, ventilating and air conditioning to the building:

AREA	HVAC UNIT	MAKE/MODEL	CFM	OA CFM	COOLING	HEATING
Basement	(2) PTAC	Gree/ ETAC2-15HC	-	-	14.2 MBH	11.7 MBH (Electric)
Intermediate Level	RTU-2	Carrier/ 48HJE008	3,000*	600*	90 MBH	147.6 MBH (Gas)
1 <sup>ST</sup> Floor	RTU-1	Carrier/ 48HJF017	6,000*	460*	180 MBH	291 MBH (Gas)

\*Original design data.

The Basement Level is provided with two packaged through the wall air conditioning units (PTAC) that provide heating and cooling to the adjacent activity spaces. There are also two enclosed storage rooms without any HVAC. The elevator machine room is provided with an inclined transfer duct to the elevator hoistway but no other HVAC provisions.

The entire Intermediate level including the two bathrooms is provided with heating, ventilating and air conditioning by RTU-2 and the roof mounted bathroom exhaust fan. The Intermediate Level occupied space consists of several different areas of different occupancy types and exterior wall exposure types. RTU-2 provides HVAC through a duct distribution system terminating into ceiling/wall air outlets and is controlled by a single wall mounted thermostat. The bathroom exhaust is through ceiling exhaust registers into the building exhaust duct distribution system terminating into the roof mounted exhaust fan. It does not appear that the crawlspace and utility room have been provided with any HVAC provisions as required by applicable codes.

The entire First Level including the two bathrooms is provided with heating, ventilating and air conditioning by RTU-1 and the roof mounted bathroom exhaust fan. The bathroom at the entry is provided with electric baseboard heat. The First Level occupied space consists of several different areas of different occupancy types, a large interior component with skylights, enclosed offices, balcony and exterior wall exposure types. RTU-1 provides HVAC through a duct distribution system terminating into ceiling/wall/floor air outlets and is controlled by a single wall mounted thermostat. The bathroom exhaust is through ceiling exhaust registers into the building exhaust duct distribution system terminating into the roof mounted exhaust fan.

The following were noted or reported to be system operational issues:

1. Uneven heating/cooling within spaces within the same air conditioning/heating zone.
2. Thermostat locations are not optimal increasing heating/cooling related issues.
3. Crawlspace, Storage, Utility and elevator machine room have not been provided with appropriate HVAC provisions.
4. System may have never been balanced and/or commissioned.

## EVALUATION

BLW Engineers performed heating, cooling and ventilation calculations for each zone of the building; the building is provided with less cooling capacity than required.

The major issues with the heating, ventilating and air conditioning system is as follows:

1. Capacity: The air conditioning capacity for each level is undersized for the areas that they serve; additional air conditioning capacity is required.
2. Zoning: The Intermediate Level and First Level are single, large heating and air conditioning zones that serve several different occupancies and exposures controlled by a single thermostat. Each zone at each level has differing heating and cooling requirements during the day as affected by the outside air temperature, location of the sun and occupancy that can't be adequately addressed by a single thermostat.
3. Thermostat Locations: Thermostat locations are not ideal; the thermostats control the heating and air conditioning of the rooftop unit. In this situation, the only space that is truly satisfied is the area that the thermostat is located; all other areas are dependent on that location.
4. Rooftop Units: The issue with gas fired/electric cool rooftop units in this particular application is that they are only capable of providing conditioned supply air when the thermostat calls for either heating or cooling; otherwise, they are providing unconditioned air at the mixed air temperature (return/outdoor air) to each space until the thermostat calls for heating or cooling although spaces outside the thermostat area already do not feel satisfied. In other words, a particular space within the single HVAC zone may already feel cold in the winter and the supply

air from the rooftop unit feels cool or the air they may feel hot in the summer time and the supply air from the rooftop unit feels warm because the thermostat is satisfied.

5. Rooftop Units: The rooftop units are at the end of their anticipated life expectancy and will need to be replaced in the near future.
6. Exhaust/Ventilation: Provisions for exhaust and ventilation should be added to crawlspace, utility room and storage rooms in conformance with applicable codes.
7. Elevator Machine Room: The elevator machine room has strict space temperature limitations; if the machine room has noted high space temperatures, a small split system should be added to adequately maintain the space temperature within the room.
8. Balancing/Commissioning: It is not clear if the systems were ever properly balanced and/or commissioned which could be significantly impacting the operation of the system.

#### ***RECOMMENDATIONS***

##### **Option 1 - Existing System Upgrades**

1. Add supplemental cooling to the building through variable refrigerant systems with individual controls to provide additional cooling capacity and zoning to each of the building systems; the interior portion of the system could include either wall or ceiling mounted units interconnected to an exterior heat pump by interconnecting refrigerant piping system with applicable controls to provide heating/cooling to individual zones throughout the building. The rooftop units and through wall units could operate to provide the first level of heating/cooling to the building while the new variable refrigerant system could provide supplemental heating and cooling to the building and offering the additional benefit of adding zoning to the individual heating and cooling zones in the building.
2. Add controls for demand control ventilation and discharge air temperature control.
3. Provide additional exhaust/ventilation systems for crawlspace, utility room and storage rooms.
4. Provide split system air conditioning system for elevator machine room.
5. Balance existing system to calculated airflows for heating and cooling.
6. Commission systems for proper sequence of operation.

The estimated construction costs for Option 1 is **\$ 119,226.00**.

##### **Option 2 – Replace Existing System**

1. Replace existing rooftop units and bathroom exhaust fan.
2. Add supplemental cooling to the building through variable refrigerant systems with individual controls to provide additional cooling capacity and zoning to each of the building systems; the interior portion of the system could include either wall or ceiling mounted units interconnected

to an exterior heat pump by interconnecting refrigerant piping system with applicable controls to provide heating/cooling to individual zones throughout the building. The rooftop units and through wall units could operate to provide the first level of heating/cooling to the building while the new variable refrigerant system could provide supplemental heating and cooling to the building and offering the additional benefit of adding zoning to the individual heating and cooling zones in the building.

3. Add building management system to remote monitor, adjust and control the entire building HVAC system.
4. Add controls for existing roof intake hoods.
5. Add controls for Lower Level Packaged Through Wall Terminal Units.
6. Add controls for demand control ventilation and discharge air temperature control.
7. Provide additional exhaust/ventilation systems for crawlspace, utility room and storage rooms.
8. Provide split system air conditioning system for elevator machine room.
9. Balance existing system to calculated airflows for heating and cooling.
10. Commission systems for proper sequence of operation.

The estimated construction costs for Option 1 is **\$ 298,056.00**.

## **Estimated Construction Costs**

BLW

BLW ENGINEERS, INC.

311 Great Road, Post Office Box 1551, Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## **Construction Cost Estimate**

Project phase: Evaluation		Project: HVAC Evaluation - Option 1						Sheet			
Trade Specification Section:		Hyde Public Library						1 of 1			
23 00 00		Sturbridge, MA						Date			
26 00 00		Project Number: 17123.00						07.28.17			
By: KRB	Checked By: KRB										
Description		Qty	Units	Material		Labor		Total			
				Unit Cost	Total	Unit Cost	Total				
<b>Option 1 - Existing System Upgrades</b>											
<b>00 10 00 - General Conditions</b>											
General Conditions											
<b>23 00 00 - HVAC</b>											
Exhaust/Ventilation Systems		1	EA	750	750	500	500	1,250			
Elevator Machine Room HVAC		1	EA	2,500	2,500	2,500	2,500	5,000			
Variable Refrigerant System		8	Tons	2,000	16,000	2,500	20,000	36,000			
Automatic Temperature Controls											
Central System		1	LS	5,000	5,000	12,500	12,500	17,500			
Demand Control Ventilation		2	EA	1,000	2,000	3,000	6,000	8,000			
Discharge Temperature Controls		2	EA	500	1,000	1,500	3,000	4,000			
Commissioning		1	LS			2,500	2,500	2,500			
Balancing		1	LS			2,500	2,500	2,500			
<b>26 00 00 - ELECTRICAL</b>											
Power Wiring		1	LS	1,500	1,500	3,500	3,500	5,000			

# BLW

## BLW ENGINEERS, INC.

311 Great Road, Post Office Box 1551, Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

### Construction Cost Estimate

Project phase:	Evaluation						Project:	HVAC Evaluation - Option 2				Sheet					
Trade Specification Section:	23 00 00 26 00 00						Hyde Public Library Sturbridge, MA				1 of 1						
By:	KRB	Checked By:	KRB	Project Number: 17123.00						Date 07.28.17							
Description			Qty	Units	Material		Labor										
Option 2 - Replace Existing System					Unit Cost	Total	Unit Cost	Total									
<b>00 10 00 - General Conditions</b>																	
General Conditions																	
<b>23 00 00 - HVAC</b>																	
Demolition			1	LS			5,000	5,000				5,000					
Rooftop Units			22.5	Tons	1,750	39,375	1,750	39,375				78,750					
Replace Bathroom Exhaust Fan			1	EA	1,500	1,500	750	750				2,250					
Exhaust/Ventilation Systems			1	EA	750	750	500	500				1,250					
Elevator Machine Room HVAC			1	EA	2,500	2,500	2,500	2,500				5,000					
Variable Refrigerant System			8	Tons	2,000	16,000	2,500	20,000				36,000					
Automatic Temperature Controls																	
Energy Managementl System			1	LS	7,500	7,500	17,500	17,500				25,000					
Rooftop Unit Controls			2	EA	2,500	5,000	7,500	15,000				20,000					
Miscellaneous Controls (Fans, Dampers, etc.)			1	LS	4,000	4,000	8,000	8,000				12,000					
Commissioning			1	LS			4,000	4,000				4,000					
Balancing			1	LS			5,000	5,000				5,000					
<b>26 00 00 - ELECTRICAL</b>																	
Power Wiring			1	LS	3,000	3,000	9,000	9,000				12,000					
Subtotal						\$ 79,625		\$ 126,625		\$ 236,250							
15% Overhead & Profit										\$ 35,438							
Subtotal										\$ 271,688							
10% Contingency										\$ 27,169							
<b>TOTAL</b>										\$ 298,856							

## **Calculations**



BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

Project phase:	Preliminary	Project:	Sturbridge Public Library			Sheet 1 of 1 <b>Date</b> 00.00.00
Trade Specification Section:	15500		b - maintenance/storage			
By:	Checked By:	Project No.:	17123			
<b>Design Conditions:</b>						
Location	Temps.	Summer		Winter		IMC 2012, IECC 2012
	Indoor	(°F-Db/°F-Wb)	75	63	70 °F	
	Outdoor	(°F-Db/°F-Wb)	88	74	9 °F	

- 1 -

I. Outdoor Air Requirement									
Area		124	ft <sup>2</sup>						
Method	Ra	A				Rp	P		
Ventilation per Person	0.06	x	124	+		5	x	1	=

12.44 CFM

per ACH

Walls	N	12	ft	x	11.25	ft	x	23	CLTD	x	0.06	Btu/hr ft2 F			=	179	Btu/hr	
	S	0	ft	x	11.25	ft	x	46	CLTD	x	0.06	Btu/hr ft2 F			=	0	Btu/hr	
	E	0	ft	x	11.25	ft	x	31	CLTD	x	0.06	Btu/hr ft2 F			=	0	Btu/hr	
	W	14	ft	x	11.25	ft	x	41	CLTD	x	0.06	Btu/hr ft2 F			=	374	Btu/hr	
	NE	0	ft	x	11.25	ft	x	29	CLTD	x	0.06	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	11.25	ft	x	37	CLTD	x	0.06	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	11.25	ft	x	19	CLTD	x	0.06	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	11.25	ft	x	26	CLTD	x	0.06	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	4	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.06	Btu/hr ft2 F						=	0	Btu/hr	
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F							0	Btu/hr	
Lighting/Power		124	ft2	x	0.90	W/ft2	x	3.412	Btuh/Watt							=	381	Btu/hr
People		1	People	x	255	Btu/hr	x	1	Diversity							=	255	Btu/hr
Infiltration		124	ft2	x	11.25	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	133	Btu/hr
												RSH			=	1,321	Btu/hr	
												Safety Factor (15%)			=	198	Btu/hr	
												ERSH			=	1,519	Btu/hr	
												Airflow (20E delta T)			=	70	CFM	

### III. Heating Load

Walls				281.25	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	1,430	Btu/hr		
Glass				0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	0	Btu/hr		
Skylight				0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	61	F	x	0.06	Btu/hr ft2 F					=	0	Btu/hr		
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Slab		20	ft	x	61	F	x	0.10	Btu/hr ft2 F					=	119	Btu/hr		
Infiltration		124	ft2	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	625	Btu/hr
(not treating air)												Heating		=	2,174	Btu/hr		
												Safety Factor (25%)		=	543	Btu/hr		
												MIN HEATING		=	2,717	Btu/hr		

#### **IV. Furnace Specifications**

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

<b>Project phase:</b>	Preliminary	<b>Project:</b>	Sturbridge Public Library b - activity space #1			<b>Sheet</b>
<b>Trade Specification Section:</b>	15500					1 of 1
<b>By:</b>	<b>Checked By:</b>		<b>Project No.:</b>	17123		
<b>Design Conditions:</b>						
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>		<b>Winter</b>		
-	<b>Indoor</b>	(°F-Db/°F-Wb)	75	63	70 °F	IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb)	88	74	9 °F	

## I. Outdoor Air Requirement

Area		320	ft <sup>2</sup>	A			Rp	P								
Ventilation	Method per Person	0.12	x	320		+		5	x	3					=	54.4 CFM
	per ACH	2.00 ACH	x	0	ft <sup>2</sup>	x	8.00	ft	/	60	min/hr				=	0 CFM

## II. Sensible Cooling Load

Walls	N	15	ft	x	11.25	ft	x	23	CLTD	x	0.33	Btu/hr ft2 F			=	1,281	Btu/hr	
	S	0	ft	x	11.25	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	E	18	ft	x	11.25	ft	x	31	CLTD	x	0.33	Btu/hr ft2 F			=	1,549	Btu/hr	
	W	0	ft	x	11.25	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NE	0	ft	x	11.25	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	11.25	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	11.25	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	11.25	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	7	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	3,018	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SF	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		7	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	350	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.06	Btu/hr ft2 F						=	0	Btu/hr	
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F						=	0	Btu/hr	
Lighting/Power		320	ft2	x	1.40	W/ft2	x	3,412	Btuh/Watt						=	1,529	Btu/hr	
People		3	People	x	255	Btu/hr	x	1	Diversity						=	816	Btu/hr	
Infiltration		320	ft2	x	11.25	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	344	Btu/hr
Sensible(w/o treating air)												RSH		=	8,886	Btu/hr		
												Safety Factor (15%)		=	1,333	Btu/hr		
												ERSH		=	10,219	Btu/hr		
												Airflow (20F delta T)		=	473	CFM		

### **III. Heating Load**

Walls				320.13	ft <sup>2</sup>	x	61	F	x	0.08	Btu/hr ft <sup>2</sup> F			=	1,627	Btu/hr		
Glass				45.50	ft <sup>2</sup>	x	61	F	x	0.55	Btu/hr ft <sup>2</sup> F			=	1,527	Btu/hr		
Skylight				0.00	ft <sup>2</sup>	x	61	F	x	0.40	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr	
Roof		0	ft <sup>2</sup>	x	61	F	x	0.06	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Floor		0	ft <sup>2</sup>	x	61	F	x	0.03	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Slab		33	ft	x	61	F	x	0.10	Btu/hr ft <sup>2</sup> F					=	201	Btu/hr		
Infiltration		320	ft <sup>2</sup>	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	1,613	Btu/hr
(not treating air)												Heating		=	4,968	Btu/hr		
												Safety Factor (25%)		=	1,242	Btu/hr		
												MIN HEATING		=	6,210	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	30.42	Btu/lb	@	79.15	F DB	,	65.68	F WB	,	11	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	473	CFM	x	7.24	BTU/lb	x	4.5						=	15,417	Btu/hr
													Tons A/C	=	1.3	Tons
													H2O (10F delta T)	=	3	GPM
														=	249	ft2/Ton
	Mix Air T-In	63	F	@	11	% OA										
	Heat Air T-Out	84	F													
	Heating Cap	473	CFM	x	21	F	x	1.08						=	10,816	Btu/hr

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

<b>Project phase:</b>	Preliminary	<b>Project:</b>	Sturbridge Public Library b - activity space #2			<b>Sheet</b>
<b>Trade Specification Section:</b>	15500					1 of 1
<b>By:</b>	<b>Checked By:</b>		<b>Project No.:</b> 17123			<b>Date</b>
<b>Design Conditions:</b>						00.00.00
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>		<b>Winter</b>		
-	<b>Indoor</b>	(°F-Db/°F-Wb)	75	63	70 °F	IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb)	88	74	9 °F	

#### I. Outdoor Air Requirement

## II. Sensible Cooling Load

### **III. Heating Load**

Walls				723.50	ft <sup>2</sup>	x	61	F	x	0.08	Btu/hr ft <sup>2</sup> F			=	3,678	Btu/hr		
Glass				22.75	ft <sup>2</sup>	x	61	F	x	0.55	Btu/hr ft <sup>2</sup> F			=	763	Btu/hr		
Skylight				0.00	ft <sup>2</sup>	x	61	F	x	0.40	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Door		3	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft <sup>2</sup> F			=	1,025	Btu/hr	
Roof		0	ft <sup>2</sup>	x	61	F	x	0.06	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Floor		0	ft <sup>2</sup>	x	61	F	x	0.03	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Slab		46	ft	x	61	F	x	0.10	Btu/hr ft <sup>2</sup> F					=	281	Btu/hr		
Infiltration		550	ft <sup>2</sup>	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	2,772	Btu/hr
(not treating air)												Heating		=	8,518	Btu/hr		
												Safety Factor (25%)		=	2,130	Btu/hr		
												MIN HEATING		=	10,648	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	31.08	Btu/lb	@	80.06	F DB	,	66.54	F WB	,	21	% OA						
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB									
	Cooling Cap	453	CFM	x	7.91	BTU/lb	x	4.5							=	16,128	Btu/hr	
														Tons A/C	=	1.3	Tons	
														H2O (10F delta T)	=	3	GPM	
															=	409	ft2/Ton	
	Mix Air T-In	57	F	@	21	% OA												
	Heat Air T-Out	94	F															
	Heating Cap	453	CFM	x	36	F	x	1.08							=	17.787	Btu/hr	

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

<b>Project phase:</b>	Preliminary	<b>Project:</b>	Sturbridge Public Library b - storage			<b>Sheet</b>
<b>Trade Specification Section:</b>	15500					1 of 1
<b>By:</b>	<b>Checked By:</b>		<b>Project No.:</b>	17123		
<b>Design Conditions:</b>						
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>		<b>Winter</b>		
-	<b>Indoor</b>	(°F-Db/°F-Wb)	75	63	70 °F	IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb)	88	74	9 °F	

#### I. Outdoor Air Requirement

Area		100	ft <sup>2</sup>	A			Rp	P							
Ventilation	Method per Person	0.06	x	100		+		5	x	0				=	6 CFM
	per ACH	2.00 ACH	x	0	ft <sup>2</sup>	x	8.00	ft	/	60	min/hr			=	0 CFM

## II. Sensible Cooling Load

Walls	N	0	ft	x	11.25	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	S	0	ft	x	11.25	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	E	0	ft	x	11.25	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	W	11	ft	x	11.25	ft	x	41	CLTD	x	0.06	Btu/hr ft2 F			=	291	Btu/hr	
	NE	0	ft	x	11.25	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	11.25	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	11.25	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	11.25	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.06	Btu/hr ft2 F						=	0	Btu/hr	
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F						=	0	Btu/hr	
Lighting/Power		100	ft2	x	0.80	W/ft2	x	3.412	Btuh/Watt						=	273	Btu/hr	
People		0	People	x	255	Btu/hr	x	1	Diversity						=	0	Btu/hr	
Infiltration		100	ft2	x	11.25	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	107	Btu/hr
Sensible(w/o treating air)												RSH	=	671	Btu/hr			
												Safety Factor (15%)	=	101	Btu/hr			
												ERSH	=	772	Btu/hr			
												Airflow (20F delta T)	=	36	CFM			

### **III. Heating Load**

Walls				118.13	ft <sup>2</sup>	x	61	F	x	0.08	Btu/hr ft <sup>2</sup> F			=	600	Btu/hr		
Glass				0.00	ft <sup>2</sup>	x	61	F	x	0.55	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Skylight				0.00	ft <sup>2</sup>	x	61	F	x	0.40	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr	
Roof		0	ft <sup>2</sup>	x	61	F	x	0.06	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Floor		0	ft <sup>2</sup>	x	61	F	x	0.03	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Infiltration		100	ft <sup>2</sup>	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	504	Btu/hr
(not treating air)												Heating		=	1,104	Btu/hr		
												Safety Factor (25%)		=	276	Btu/hr		
												MIN HEATING		=	1,381	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	30.80	Btu/lb	@	79.68	F DB	,	66.18	F WB	,	17	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	36	CFM	x	7.63	BTU/lb	x	4.5						=	1,226	Btu/hr
													Tons A/C	=	0.1	Tons
													H2O (10F delta T)	=	0	GPM
														=	979	ft2/Ton
	Mix Air T-In	60	F	@	17	% OA										
	Heat Air T-Out	108	F													
	Heating Cap	36	CFM	x	48	F	x	1.08						=	1,853	Btu/hr

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

<b>Project phase:</b>	Preliminary	<b>Project:</b>	<b>Sturbridge Public Libra</b>		<b>Sheet</b>
<b>Trade Specification Section:</b>	15500		b - elevator mach. Rm.		1 of 1
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b>	17123		<b>Date</b>
<b>Design Conditions:</b>					
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>		<b>Winter</b>	
-	<b>Indoor</b>	(°F-Db/°F-Wb)	75	63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb)	88	74	9 °F

### I. Outdoor Air Requirement

Area		67	ft <sup>2</sup>	A			Rp	P								
Ventilation	Method per Person	0.06	x	67		+									=	4.02 CFM
	per ACH	2.00 ACH	x	0	ft <sup>2</sup>	x	8.00	ft	5	x	0				=	0 CFM

## II. Sensible Cooling Load

### **III. Heating Load**

Walls				81.56	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	415	Btu/hr		
Glass				0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	0	Btu/hr		
Skylight				0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	61	F	x	0.06	Btu/hr ft2 F					=	0	Btu/hr		
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F					=	0	Btu/hr		
Infiltration		67	ft2	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	338	Btu/hr
(not treating air)												Heating		=	752	Btu/hr		
												Safety Factor (25%)		=	188	Btu/hr		
												MIN HEATING		=	940	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	30.33	Btu/lb	@	79.03	F DB	,	65.57	F WB	,	10	% OA						
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB									
	Cooling Cap	39	CFM	x	7.16	BTU/lb	x	4.5							=	1,252	Btu/hr	
														Tons A/C	=	0.1	Tons	
														H2O (10F delta T)	=	0	GPM	
															=	642	ft2/Ton	
	Mix Air T-In	64	F	@	10	% OA												
	Heat Air T-Out	94	F															
	Heating Cap	39	CFM	x	31	F	x	1.08							=	1,289	Btu/hr	

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

#### I. Outdoor Air Requirement

Area		127	ft <sup>2</sup>	A			Rp	P						
Ventilation	Method per Person	0.06	x	127		+								=
	per ACH	2.00 ACH	x	0	ft <sup>2</sup>	x	8.00	ft	5 x 0	/ 60	min/hr			= 7.62 CFM 0 CFM

## II. Sensible Cooling Load

### III. Heating Load

Walls				421.88	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	2,145	Btu/hr		
Glass				0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	0	Btu/hr		
Skylight				0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr		
Door		3	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	1,025	Btu/hr	
Roof		0	ft2	x	61	F	x	0.06	Btu/hr ft2 F					=	0	Btu/hr		
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F					=	0	Btu/hr		
Infiltration		127	ft2	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	640	Btu/hr
(not treating air)												Heating		=	3,809	Btu/hr		
												Safety Factor (25%)		=	952	Btu/hr		
												MIN HEATING		=	4,762	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	30.26	Btu/lb	@	78.93	F DB	,	65.47	F WB	,	9	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	82	CFM	x	7.08	BTU/lb	x	4.5						=	2,622	Btu/hr
												Tons A/C		=	0.2	Tons
												H2O (10F delta T)		=	1	GPM
														=	581	ft2/Ton
	Mix Air T-In	64	F	@	9	% OA										
	Heat Air T-Out	126	F													
	Heating Cap	82	CFM	x	61	F	x	1.08						=	5,441	Btu/hr

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b>	Preliminary	<b>Project:</b>	<b>Sturbridge Public Library</b>	<b>Sheet</b>
<b>Trade Specification Section:</b>	15500		1 - atrium & wings	1 of 1
<b>Date</b>				
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b>	17123	00.00.00
<b>Design Conditions:</b>				
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>	
-	Indoor	(°F-Db/°F-Wb) 75	63	70 °F IMC 2012, IECC 2012
	Outdoor	(°F-Db/°F-Wb) 88	74	9 °F

#### I. Outdoor Air Requirement

Area		1,848	ft <sup>2</sup>	A			Rp	P							
Ventilation	Method per Person	0.12	x	1,848		+			5	x	18			=	314.16 CFM
	per ACH	2.00 ACH	x	0	ft <sup>2</sup>	x	8.00	ft	/	60	min/hr			=	0 CFM

## II. Sensible Cooling Load

### **III. Heating Load**

Walls				1349.44	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	6,860	Btu/hr		
Glass				234.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	7,851	Btu/hr		
Skylight				0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	61	F	x	0.06	Btu/hr ft2 F					=	0	Btu/hr		
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F					=	0	Btu/hr		
Infiltration		1,848	ft2	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	9,314	Btu/hr
(not treating air)												Heating		=	24,024	Btu/hr		
												Safety Factor (25%)		=	6,006	Btu/hr		
												MIN HEATING		=	30,030	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	30.78	Btu/lb	@	79.65	F DB	,	66.15	F WB	,	17	% OA					
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB								
	Cooling Cap	1,899	CFM	x	7.61	BTU/lb	x	4.5							=	65,012 Btu/hr	
														Tons A/C	=	5.4 Tons	
														H2O (10F delta T)	=	13 GPM	
	Mix Air T-In	60	F	@	17	% OA										=	341 ft <sup>2</sup> /Ton
	Heat Air T-Out	87	F														
	Heating Cap	1,899	CFM	x	27	F	x	1.08							=	54,829 Btu/hr	

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

<b>Project phase:</b>	Preliminary	<b>Project:</b>	Sturbridge Public Library			<b>Sheet</b>
<b>Trade Specification Section:</b>	15500		1 - utility room			1 of 1
<b>Date</b>						
<b>By:</b>	<b>Checked By:</b>		<b>Project No.:</b>	17123		00.00.00
<b>Design Conditions:</b>						
<b>Location</b>		<b>Temps.</b>	<b>Summer</b>		<b>Winter</b>	
-		Indoor	(°F-Db/°F-Wb)	75	63	70 °F IMC 2012, IECC 2012
		Outdoor	(°F-Db/°F-Wb)	88	74	9 °F

#### I. Outdoor Air Requirement

Area		309	ft <sup>2</sup>	A			Rp	P							
Ventilation	Method per Person	0.06	x	309		+									= 18.54 CFM
	per ACH	2.00 ACH	x	0	ft <sup>2</sup>	x	8.00	ft	5 x 0 / 60	min/hr					= 0 CFM

## II. Sensible Cooling Load

Walls	N	0	ft	x	11.25	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	S	0	ft	x	11.25	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	E	0	ft	x	11.25	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	W	0	ft	x	11.25	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NE	0	ft	x	11.25	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	11.25	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	11.25	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	11.25	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.06	Btu/hr ft2 F						=	0	Btu/hr	
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F						=	0	Btu/hr	
Lighting/Power		309	ft2	x	2.00	W/ft2	x	3.412	Btuh/Watt						=	2,109	Btu/hr	
People		0	People	x	255	Btu/hr	x	1	Diversity						=	0	Btu/hr	
Infiltration		0	ft2	x	11.25	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	0	Btu/hr
												RSH			=	2,109	Btu/hr	
												Safety Factor (15%)			=	316	Btu/hr	
												ERSH			=	2,425	Btu/hr	
												Airflow (20F delta T)			=	112	CFM	
												Sensible(w/o treating air)						

### III. Heating Load

Walls				0.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass				0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	0	Btu/hr	
Skylight				0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Door	0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	0	Btu/hr	
Roof	0	ft2	x	61	F	x	0.06	Btu/hr ft2 F						=	0	Btu/hr	
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F						=	0	Btu/hr	
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F						=	0	Btu/hr	
Infiltration	0	ft2	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	0	Btu/hr
(not treating air)												<b>Heating</b>		=	0	Btu/hr	
												<b>Safety Factor (25%)</b>		=	0	Btu/hr	
												<b>MIN HEATING</b>		=	<b>0</b>	<b>Btu/hr</b>	

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	30.78	Btu/lb	@	79.65	F DB	,	66.15	F WB	,	17	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	112	CFM	x	7.60	BTU/lb	x	4.5							=	3,842 Btu/hr
														Tons A/C	=	0.3 Tons
														H2O (10F delta T)	=	1 GPM
	Mix Air T-In	60	F	@	17	% OA									=	965 ft2/Ton
	Heat Air T-Out	72	F													
	Heating Cap	112	CFM	x	12	F	x	1.08							=	1,464 Btu/hr

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

#### I. Outdoor Air Requirement

Area		142	ft <sup>2</sup>	A			Rp	P						
Ventilation	Method per Person	0.06	x	142		+								=
	per ACH	2.00 ACH	x	0	ft <sup>2</sup>	x	8.00	ft	5 x 0	/ 60	min/hr			= 8.52 CFM 0 CFM

## II. Sensible Cooling Load

Walls	N	8	ft	x	11.25	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	173	Btu/hr	
	S	0	ft	x	11.25	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	E	0	ft	x	11.25	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	W	0	ft	x	11.25	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NE	0	ft	x	11.25	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	11.25	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	11.25	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	11.25	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.06	Btu/hr ft2 F						=	0	Btu/hr	
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F						=	0	Btu/hr	
Lighting/Power		142	ft2	x	0.60	W/ft2	x	3.412	Btuh/Watt						=	291	Btu/hr	
People		0	People	x	255	Btu/hr	x	1	Diversity						=	0	Btu/hr	
Infiltration		142	ft2	x	11.25	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	153	Btu/hr
												RSH			=	616	Btu/hr	
												Safety Factor (15%)			=	92	Btu/hr	
												ERSH			=	708	Btu/hr	
												Airflow (20F delta T)			=	33	CFM	
												Sensible(w/o treating air)						

### **III. Heating Load**

Walls				90.00	ft <sup>2</sup>	x	61	F	x	0.08	Btu/hr ft <sup>2</sup> F			=	458	Btu/hr		
Glass				0.00	ft <sup>2</sup>	x	61	F	x	0.55	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Skylight				0.00	ft <sup>2</sup>	x	61	F	x	0.40	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Door		3	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft <sup>2</sup> F			=	1,025	Btu/hr	
Roof		0	ft <sup>2</sup>	x	61	F	x	0.06	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Floor		0	ft <sup>2</sup>	x	61	F	x	0.03	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Infiltration		142	ft <sup>2</sup>	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	716	Btu/hr
(not treating air)												Heating		=	2,198	Btu/hr		
												Safety Factor (25%)		=	549	Btu/hr		
												MIN HEATING		=	2,747	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	31.48	Btu/lb	@	80.60	F DB	,	67.04	F WB	,	26	% OA					
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB								
	Cooling Cap	33	CFM	x	8.30	BTU/lb	x	4.5						=	1,225	Btu/hr	
													Tons A/C	=	0.1	Tons	
													H2O (10F delta T)	=	0	GPM	
	Mix Air T-In	54	F	@	26	% OA									=	1391	ft2/Ton
	Heat Air T-Out	150	F														
	Heating Cap	33	CFM	x	95	F	x	1.08						=	3,380	Btu/hr	

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

#### I. Outdoor Air Requirement

## II. Sensible Cooling Load

### III. Heating Load

Walls				39.38	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	200	Btu/hr		
Glass				0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	0	Btu/hr		
Skylight				0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	61	F	x	0.06	Btu/hr ft2 F					=	0	Btu/hr		
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F					=	0	Btu/hr		
Infiltration		21	ft2	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	106	Btu/hr
(not treating air)												Heating		=	306	Btu/hr		
												Safety Factor (25%)		=	76	Btu/hr		
												MIN HEATING		=	382	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	30.29	Btu/lb	@	78.98	F DB	,	65.52	F WB	,	10	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	13	CFM	x	7.12	BTU/lb	x	4.5						=	412	Btu/hr
													Tons A/C	=	0.0	Tons
													H2O (10F delta T)	=	0	GPM
														=	612	ft2/Ton
	Mix Air T-In	64	F	@	10	% OA										
	Heat Air T-Out	100	F													
	Heating Cap	13	CFM	x	36	F	x	1.08						=	493	Btu/hr

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

#### I. Outdoor Air Requirement

Area		134	ft <sup>2</sup>	A			Rp	P							
Ventilation	Method per Person	0.06	x	134		+									= 18.04 CFM
	per ACH	2.00 ACH	x	0	ft <sup>2</sup>	x	8.00	ft	5 x 2	/ 60	min/hr				= 0 CFM

## II. Sensible Cooling Load

### **III. Heating Load**

Walls				106.88	ft <sup>2</sup>	x	61	F	x	0.08	Btu/hr ft <sup>2</sup> F			=	543	Btu/hr		
Glass				0.00	ft <sup>2</sup>	x	61	F	x	0.55	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Skylight				0.00	ft <sup>2</sup>	x	61	F	x	0.40	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr	
Roof		0	ft <sup>2</sup>	x	61	F	x	0.06	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Floor		0	ft <sup>2</sup>	x	61	F	x	0.03	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Infiltration		134	ft <sup>2</sup>	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	675	Btu/hr
(not treating air)												Heating		=	1,219	Btu/hr		
												Safety Factor (25%)		=	305	Btu/hr		
												MIN HEATING		=	1,523	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	31.53	Btu/lb	@	80.67	F DB	,	67.11	F WB	,	27	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	68	CFM	x	8.35	BTU/lb	x	4.5						=	2,542	Btu/hr
													Tons A/C	=	0.2	Tons
													H2O (10F delta T)	=	1	GPM
														=	633	ft2/Ton
	Mix Air T-In	54	F	@	27	% OA										
	Heat Air T-Out	93	F													
	Heating Cap	68	CFM	x	39	F	x	1.08						=	2,858	Btu/hr

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

<b>Project phase:</b>	Preliminary	<b>Project:</b>	Sturbridge Public Library		<b>Sheet</b>
<b>Trade Specification Section:</b>	15500		1 - men's rm		1 of 1
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b>	17123		<b>Date</b>
<b>Design Conditions:</b>					
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>		<b>Winter</b>	
-	<b>Indoor</b>	(°F-Db/°F-Wb)	75	63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb)	88	74	9 °F

#### I. Outdoor Air Requirement

Area		134	ft <sup>2</sup>	A			Rp	P							
Ventilation	Method per Person	0.06	x	134		+									= 18.04 CFM
	per ACH	2.00 ACH	x	0	ft <sup>2</sup>	x	8.00	ft	5 x 2	/ 60	min/hr				= 0 CFM

## II. Sensible Cooling Load

### **III. Heating Load**

Walls				97.43	ft <sup>2</sup>	x	61	F	x	0.08	Btu/hr ft <sup>2</sup> F			=	495	Btu/hr		
Glass				0.00	ft <sup>2</sup>	x	61	F	x	0.55	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Skylight				0.00	ft <sup>2</sup>	x	61	F	x	0.40	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr	
Roof		0	ft <sup>2</sup>	x	61	F	x	0.06	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Floor		0	ft <sup>2</sup>	x	61	F	x	0.03	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Infiltration		134	ft <sup>2</sup>	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	675	Btu/hr
(not treating air)												Heating		=	1,171	Btu/hr		
												Safety Factor (25%)		=	293	Btu/hr		
												MIN HEATING		=	1,463	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	31.56	Btu/lb	@	80.71	F DB	,	67.14	F WB	,	27	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	67	CFM	x	8.38	BTU/lb	x	4.5						=	2,514	Btu/hr
													Tons A/C	=	0.2	Tons
													H2O (10F delta T)	=	1	GPM
														=	640	ft2/Ton
	Mix Air T-In	53	F	@	27	% OA										
	Heat Air T-Out	92	F													
	Heating Cap	67	CFM	x	39	F	x	1.08						=	2,796	Btu/hr

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

<b>Project phase:</b>	Preliminary	<b>Project:</b>	Sturbridge Public Libra			<b>Sheet</b>
<b>Trade Specification Section:</b>	15500		1 - stair #2			1 of 1
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b>	17123			<b>Date</b>
						00.00.00
<b>Design Conditions:</b>						
<b>Location</b>		<b>Temps.</b>	<b>Summer</b>		<b>Winter</b>	
-		<b>Indoor</b>	(°F-Db/°F-Wb)	75	63	70 °F IMC 2012, IECC 2012
		<b>Outdoor</b>	(°F-Db/°F-Wb)	88	74	9 °F

#### I. Outdoor Air Requirement

## II. Sensible Cooling Load

Walls	N	9	ft	x	11.25	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	194	Btu/hr	
	S	9	ft	x	11.25	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	388	Btu/hr	
	E	20	ft	x	11.25	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	522	Btu/hr	
	W	0	ft	x	11.25	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NE	0	ft	x	11.25	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	11.25	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	11.25	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	11.25	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	4	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	1,509	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		4	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	175	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.06	Btu/hr ft2 F						=	0	Btu/hr	
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F						=	0	Btu/hr	
Lighting/Power		123	ft2	x	0.60	W/ft2	x	3.412	Btuh/Watt						=	252	Btu/hr	
People		0	People	x	255	Btu/hr	x	1	Diversity						=	0	Btu/hr	
Infiltration		123	ft2	x	11.25	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	132	Btu/hr
												RSH			=	3,173	Btu/hr	
												Safety Factor (15%)			=	476	Btu/hr	
												ERSH			=	3,649	Btu/hr	
												Airflow (20F delta T)			=	169	CFM	
												Sensible(w/o treating air)						

### **III. Heating Load**

Walls				404.75	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	2,057	Btu/hr		
Glass				22.75	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	763	Btu/hr		
Skylight				0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	61	F	x	0.06	Btu/hr ft2 F					=	0	Btu/hr		
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F					=	0	Btu/hr		
Infiltration		123	ft2	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	620	Btu/hr
(not treating air)												Heating		=	3,441	Btu/hr		
												Safety Factor (25%)		=	860	Btu/hr		
												MIN HEATING		=	4,301	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	29.91	Btu/lb	@	78.44	F DB	,	65.01	F WB	,	4	% OA						
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB									
	Cooling Cap	169	CFM	x	6.73	BTU/lb	x	4.5							=	5,117	Btu/hr	
														Tons A/C	=	0.4	Tons	
														H2O (10F delta T)	=	1	GPM	
															=	288	ft2/Ton	
	Mix Air T-In	67	F	@	4	% OA												
	Heat Air T-Out	96	F															
	Heating Cap	169	CFM	x	28	F	x	1.08							=	5,152	Btu/hr	

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

<b>Project phase:</b>	Preliminary	<b>Project:</b>	<b>Sturbridge Public Library</b>	<b>Sheet</b>
<b>Trade Specification Section:</b>	15500		2 - west	1 of 1
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b>	17123	<b>Date</b>
				00.00.00
<b>Design Conditions:</b>				
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>	
-	Indoor	(°F-Db/°F-Wb)	75	63      70 °F    IMC 2012, IECC 2012
	Outdoor	(°F-Db/°F-Wb)	88	74      9 °F

#### I. Outdoor Air Requirement

## II. Sensible Cooling Load

Walls	N	34	ft	x	16.50	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F		=	916	Btu/hr		
	S	34	ft	x	16.50	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F		=	1,857	Btu/hr		
	E	5	ft	x	16.50	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F		=	192	Btu/hr		
	W	42	ft	x	16.50	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F		=	2,029	Btu/hr		
	NE	0	ft	x	11.25	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	SE	0	ft	x	11.25	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	NW	7	ft	x	16.50	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F		=	189	Btu/hr		
	SW	7	ft	x	16.50	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F		=	259	Btu/hr		
Glass	N	12	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	2,382	Btu/hr
	S	11	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	5,486	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	14	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	4,731	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		36	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F		=	1,802	Btu/hr		
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F		=	0	Btu/hr		
Roof		966	ft2	x	40.00	CLTD	x	0.06	Btu/hr ft2 F						=	2,147	Btu/hr	
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F						=	0	Btu/hr	
Lighting/Power		1,342	ft2	x	1.40	W/ft2	x	3.412	Btuh/Watt						=	6,410	Btu/hr	
People		13	People	x	255	Btu/hr	x	1	Diversity						=	3,422	Btu/hr	
Infiltration		1,342	ft2	x	11.25	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	1,441	Btu/hr
Sensible(w/o treating air)												RSH	=	33,265	Btu/hr			
												Safety Factor (15%)	=	4,990	Btu/hr			
												ERSH	=	38,255	Btu/hr			
												Airflow (20F delta T)	=	1,771	CFM			

### **III. Heating Load**

Walls				1869.75	ft2	x	61	F	x	0.08	Btu/hr ft2 F		=	9,505	Btu/hr		
Glass				234.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F		=	7,851	Btu/hr		
Skylight				0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F		=	0	Btu/hr		
Door	3	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F		=	1,025	Btu/hr		
Roof	966	ft2	x	61	F	x	0.06	Btu/hr ft2 F					=	3,274	Btu/hr		
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F					=	0	Btu/hr		
Infiltration	1,342	ft2	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	6,763	Btu/hr
(not treating air)												Heating	=	28,417	Btu/hr		
												Safety Factor (25%)	=	7,104	Btu/hr		
												MIN HEATING	=	35,521	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	30.52	Btu/lb	@	79.29	F DB	,	65.81	F WB	,	13	% OA						
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB									
	Cooling Cap	1,771	CFM	x	7.34	BTU/lb	x	4.5							=	58,509	Btu/hr	
														Tons A/C	=	4.9	Tons	
														H2O (10F delta T)	=	12	GPM	
															=	275	ft2/Ton	
	Mix Air T-In	62	F	@	13	% OA												
	Heat Air T-Out	91	F															
	Heating Cap	1,771	CFM	x	28	F	x	1.08							=	54,377	Btu/hr	

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

#### I. Outdoor Air Requirement

Area		1,914	ft <sup>2</sup>	A			Rp	P								
Ventilation	Method per Person	0.12	x	1,914		+										= 325.38 CFM
	per ACH	2.00 ACH	x	0	ft <sup>2</sup>	x	8.00	ft	/ 60	min/hr						= 0 CFM

## II. Sensible Cooling Load

### **III. Heating Load**

Walls				1559.87	ft <sup>2</sup>	x	61	F	x	0.08	Btu/hr ft <sup>2</sup> F			=	7,929	Btu/hr	
Glass				273.00	ft <sup>2</sup>	x	61	F	x	0.55	Btu/hr ft <sup>2</sup> F			=	9,159	Btu/hr	
Skylight				460.00	ft <sup>2</sup>	x	61	F	x	0.40	Btu/hr ft <sup>2</sup> F			=	11,224	Btu/hr	
Door	0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr	
Roof	2,818	ft <sup>2</sup>	x	61	F	x	0.06	Btu/hr ft <sup>2</sup> F						=	9,550	Btu/hr	
Floor	0	ft <sup>2</sup>	x	61	F	x	0.03	Btu/hr ft <sup>2</sup> F						=	0	Btu/hr	
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft <sup>2</sup> F						=	0	Btu/hr	
Infiltration	1,914	ft <sup>2</sup>	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	9,646	Btu/hr
(not treating air)												Heating		=	47,509	Btu/hr	
												Safety Factor (25%)		=	11,877	Btu/hr	
												MIN HEATING		=	59,386	Btu/hr	

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	30.61	Btu/lb	@	79.42	F DB	,	65.93	F WB	,	14	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	2,292	CFM	x	7.44	BTU/lb	x	4.5						=	76,698	Btu/hr
													Tons A/C	=	6.4	Tons
													H2O (10F delta T)	=	15	GPM
														=	299	ft2/Ton
	Mix Air T-In	61	F	@	14	% OA										
	Heat Air T-Out	96	F													
	Heating Cap	2,292	CFM	x	35	F	x	1.08						=	85,772	Btu/hr

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

<b>Project phase:</b>	Preliminary	<b>Project:</b>	<b>Sturbridge Public Libra</b>		<b>Sheet</b>
<b>Trade Specification Section:</b>	15500		2 - stair #2		1 of 1
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b>	17123		<b>Date</b>
<b>Design Conditions:</b>					
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>		<b>Winter</b>	
-	<b>Indoor</b>	(°F-Db/°F-Wb)	75	63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb)	88	74	9 °F

#### I. Outdoor Air Requirement

Area		123	ft <sup>2</sup>	A			Rp	P							
Ventilation	Method per Person	0.06	x	123		+		5	x	0				=	7.38 CFM
	per ACH	2.00 ACH	x	0	ft <sup>2</sup>	x	8.00	ft	/	60	min/hr			=	0 CFM

## II. Sensible Cooling Load

Walls	N	9	ft	x	16.50	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	277	Btu/hr	
	S	9	ft	x	16.50	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	553	Btu/hr	
	E	20	ft	x	16.50	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	772	Btu/hr	
	W	0	ft	x	11.25	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NE	0	ft	x	11.25	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	11.25	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	11.25	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	11.25	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	4	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	1,509	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SF	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		4	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	175	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		256	ft2	x	40.00	CLTD	x	0.06	Btu/hr ft2 F						=	569	Btu/hr	
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F						=	0	Btu/hr	
Lighting/Power		123	ft2	x	0.60	W/ft2	x	3,412	Btuh/Watt						=	252	Btu/hr	
People		0	People	x	255	Btu/hr	x	1	Diversity						=	0	Btu/hr	
Infiltration		123	ft2	x	11.25	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	132	Btu/hr
Sensible(w/o treating air)												RSH	=	4,240	Btu/hr			
												Safety Factor (15%)	=	636	Btu/hr			
												ERSH	=	4,876	Btu/hr			
												Airflow (20F delta T)	=	226	CFM			

### **III. Heating Load**

Walls				587.75	ft <sup>2</sup>	x	61	F	x	0.08	Btu/hr ft <sup>2</sup> F			=	2,988	Btu/hr		
Glass				22.75	ft <sup>2</sup>	x	61	F	x	0.55	Btu/hr ft <sup>2</sup> F			=	763	Btu/hr		
Skylight				0.00	ft <sup>2</sup>	x	61	F	x	0.40	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr	
Roof		256	ft <sup>2</sup>	x	61	F	x	0.06	Btu/hr ft <sup>2</sup> F					=	868	Btu/hr		
Floor		0	ft <sup>2</sup>	x	61	F	x	0.03	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Infiltration		123	ft <sup>2</sup>	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	620	Btu/hr
(not treating air)												Heating		=	5,238	Btu/hr		
												Safety Factor (25%)		=	1,310	Btu/hr		
												MIN HEATING		=	6,548	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	29.83	Btu/lb	@	78.33	F DB	,	64.91	F WB	,	3	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	226	CFM	x	6.65	BTU/lb	x	4.5						=	6,759	Btu/hr
												Tons A/C		=	0.6	Tons
												H2O (10F delta T)		=	1	GPM
														=	218	ft2/Ton
	Mix Air T-In	68	F	@	3	% OA										
	Heat Air T-Out	99	F													
	Heating Cap	226	CFM	x	31	F	x	1.08						=	7,522	Btu/hr

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

<b>Project phase:</b>	Preliminary	<b>Project:</b>	Sturbridge Public Library	<b>Sheet</b>
<b>Trade Specification Section:</b>	15500		2 - office #1	1 of 1
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b>	17123	<b>Date</b>
				00.00.00
<b>Design Conditions:</b>				
Location		Temps.	Summer	Winter
-		Indoor	(°F-Db/°F-Wb) 75	63      70 °F    IMC 2012, IECC 2012
		Outdoor	(°F-Db/°F-Wb) 88	74      9 °F

#### I. Outdoor Air Requirement

Area		133	ft <sup>2</sup>	A			Rp	P							
Ventilation	Method per Person	0.06	x	133		+		5	x	1				=	11.305 CFM
	per ACH	2.00 ACH	x	0	ft <sup>2</sup>	x	8.00	ft	/	60	min/hr			=	0 CFM

## II. Sensible Cooling Load

Walls	N	10	ft	x	11.25	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	172	Btu/hr	
	S	0	ft	x	11.25	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	E	0	ft	x	11.25	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	W	0	ft	x	11.25	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NE	0	ft	x	11.25	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	11.25	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	11.25	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	11.25	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	4	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	725	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SF	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		4	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	175	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		133	ft2	x	40.00	CLTD	x	0.06	Btu/hr ft2 F						=	296	Btu/hr	
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F						=	0	Btu/hr	
Lighting/Power		133	ft2	x	1.10	W/ft2	x	3.412	Btuh/Watt						=	499	Btu/hr	
People		1	People	x	255	Btu/hr	x	1	Diversity						=	170	Btu/hr	
Infiltration		133	ft2	x	11.25	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	143	Btu/hr
Sensible(w/o treating air)												RSH	=	2,179	Btu/hr			
												Safety Factor (15%)	=	327	Btu/hr			
												ERSH	=	2,506	Btu/hr			
												Airflow (20F delta T)	=	116	CFM			

### **III. Heating Load**

Walls				89.75	ft <sup>2</sup>	x	61	F	x	0.08	Btu/hr ft <sup>2</sup> F			=	456	Btu/hr		
Glass				22.75	ft <sup>2</sup>	x	61	F	x	0.55	Btu/hr ft <sup>2</sup> F			=	763	Btu/hr		
Skylight				0.00	ft <sup>2</sup>	x	61	F	x	0.40	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr	
Roof		133	ft <sup>2</sup>	x	61	F	x	0.06	Btu/hr ft <sup>2</sup> F					=	451	Btu/hr		
Floor		0	ft <sup>2</sup>	x	61	F	x	0.03	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Infiltration		133	ft <sup>2</sup>	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	670	Btu/hr
(not treating air)												Heating		=	2,341	Btu/hr		
												Safety Factor (25%)		=	585	Btu/hr		
												MIN HEATING		=	2,926	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	30.29	Btu/lb	@	78.97	F DB	,	65.52	F WB	,	10	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	116	CFM	x	7.12	BTU/lb	x	4.5						=	3,715	Btu/hr
													Tons A/C	=	0.3	Tons
													H2O (10F delta T)	=	1	GPM
														=	430	ft2/Ton
	Mix Air T-In	64	F	@	10	% OA										
	Heat Air T-Out	95	F													
	Heating Cap	116	CFM	x	31	F	x	1.08						=	3,921	Btu/hr

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

<b>Project phase:</b>	Preliminary	<b>Project:</b>	Sturbridge Public Library			<b>Sheet</b>
<b>Trade Specification Section:</b>	15500		2 - office #2			1 of 1
<b>Date</b>						
<b>By:</b>	<b>Checked By:</b>		<b>Project No.:</b> 17123			00.00.00
<b>Design Conditions:</b>						
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>		<b>Winter</b>		
-	<b>Indoor</b>	(°F-Db/°F-Wb)	75	63	70 °F	IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb)	88	74	9 °F	

#### I. Outdoor Air Requirement

## II. Sensible Cooling Load

Walls	N	0	ft	x	11.25	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	S	12	ft	x	11.25	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	409	Btu/hr	
	E	0	ft	x	11.25	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	W	0	ft	x	11.25	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NE	0	ft	x	11.25	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	11.25	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	11.25	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	11.25	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	4	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	1,829	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		4	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	175	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		163	ft2	x	40.00	CLTD	x	0.06	Btu/hr ft2 F						=	362	Btu/hr	
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F						=	0	Btu/hr	
Lighting/Power		163	ft2	x	1.10	W/ft2	x	3.412	Btuh/Watt						=	612	Btu/hr	
People		1	People	x	255	Btu/hr	x	1	Diversity						=	208	Btu/hr	
Infiltration		163	ft2	x	11.25	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	175	Btu/hr
												RSH		=	3,770	Btu/hr		
												Safety Factor (15%)		=	565	Btu/hr		
												ERSH		=	4,335	Btu/hr		
												Airflow (20F delta T)		=	201	CFM		
												Sensible(w/o treating air)						

### **III. Heating Load**

Walls				106.63	ft <sup>2</sup>	x	61	F	x	0.08	Btu/hr ft <sup>2</sup> F			=	542	Btu/hr		
Glass				22.75	ft <sup>2</sup>	x	61	F	x	0.55	Btu/hr ft <sup>2</sup> F			=	763	Btu/hr		
Skylight				0.00	ft <sup>2</sup>	x	61	F	x	0.40	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr	
Roof		163	ft <sup>2</sup>	x	61	F	x	0.06	Btu/hr ft <sup>2</sup> F					=	552	Btu/hr		
Floor		0	ft <sup>2</sup>	x	61	F	x	0.03	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Infiltration		163	ft <sup>2</sup>	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	821	Btu/hr
(not treating air)												Heating		=	2,679	Btu/hr		
												Safety Factor (25%)		=	670	Btu/hr		
												MIN HEATING		=	3,349	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	30.09	Btu/lb	@	78.69	F DB	,	65.25	F WB	,	7	% OA						
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB									
	Cooling Cap	201	CFM	x	6.91	BTU/lb	x	4.5							=	6,243	Btu/hr	
														Tons A/C	=	0.5	Tons	
														H2O (10F delta T)	=	1	GPM	
	Mix Air T-In	66	F	@	7	% OA										=	313	ft2/Ton
	Heat Air T-Out	87	F															
	Heating Cap	201	CFM	x	22	F	x	1.08								=	4,695	Btu/hr

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

<b>Project phase:</b>	Preliminary	<b>Project:</b>	Sturbridge Public Library	<b>Sheet</b>
<b>Trade Specification Section:</b>	15500		2 - office #3	1 of 1
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b>	17123	<b>Date</b>
				00.00.00
<b>Design Conditions:</b>				
Location		Temps.	Summer	Winter
-		Indoor	(°F-Db/°F-Wb) 75	63      70 °F    IMC 2012, IECC 2012
		Outdoor	(°F-Db/°F-Wb) 88	74      9 °F

### I. Outdoor Air Requirement

Area		126	ft <sup>2</sup>	A			Rp	P							
Ventilation	Method per Person	0.06	x	126		+		5	x	1				=	10.71 CFM
	per ACH	2.00 ACH	x	0	ft <sup>2</sup>	x	8.00	ft	/	60	min/hr			=	0 CFM

## II. Sensible Cooling Load

Walls	N	0	ft	x	11.25	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	S	9	ft	x	11.25	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	312	Btu/hr	
	E	0	ft	x	11.25	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	W	0	ft	x	11.25	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NE	0	ft	x	11.25	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	11.25	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	11.25	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	11.25	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	4	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	1,829	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		4	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	175	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		126	ft2	x	40.00	CLTD	x	0.06	Btu/hr ft2 F							=	280	Btu/hr
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F							=	0	Btu/hr
Lighting/Power		126	ft2	x	1.10	W/ft2	x	3.412	Btuh/Watt							=	473	Btu/hr
People		1	People	x	255	Btu/hr	x	1	Diversity							=	161	Btu/hr
Infiltration		126	ft2	x	11.25	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	135	Btu/hr
												RSH			=	3,365	Btu/hr	
												Safety Factor (15%)			=	505	Btu/hr	
												ERSH			=	3,869	Btu/hr	
												Airflow (20F delta T)			=	179	CFM	
												Sensible(w/o treating air)						

### **III. Heating Load**

Walls				81.31	ft <sup>2</sup>	x	61	F	x	0.08	Btu/hr ft <sup>2</sup> F			=	413	Btu/hr		
Glass				22.75	ft <sup>2</sup>	x	61	F	x	0.55	Btu/hr ft <sup>2</sup> F			=	763	Btu/hr		
Skylight				0.00	ft <sup>2</sup>	x	61	F	x	0.40	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr	
Roof		126	ft <sup>2</sup>	x	61	F	x	0.06	Btu/hr ft <sup>2</sup> F					=	427	Btu/hr		
Floor		0	ft <sup>2</sup>	x	61	F	x	0.03	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Infiltration		126	ft <sup>2</sup>	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	635	Btu/hr
(not treating air)												Heating		=	2,239	Btu/hr		
												Safety Factor (25%)		=	560	Btu/hr		
												MIN HEATING		=	2,798	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	30.02	Btu/lb	@	78.60	F DB	,	65.16	F WB	,	6	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	179	CFM	x	6.85	BTU/lb	x	4.5						=	5,519	Btu/hr
													Tons A/C	=	0.5	Tons
													H2O (10F delta T)	=	1	GPM
														=	274	ft2/Ton
	Mix Air T-In	66	F	@	6	% OA										
	Heat Air T-Out	86	F													
	Heating Cap	179	CFM	x	20	F	x	1.08						=	3,891	Btu/hr

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

## I. Outdoor Air Requirement

Area		134	ft <sup>2</sup>	A			Rp	P							
Ventilation	Method per Person	0.06	x	134		+		5	x	1				=	11.39 CFM
	per ACH	2.00 ACH	x	0	ft <sup>2</sup>	x	8.00	ft	/	60	min/hr			=	0 CFM

## II. Sensible Cooling Load

### III. Heating Load

Walls				87.50	ft <sup>2</sup>	x	61	F	x	0.08	Btu/hr ft <sup>2</sup> F			=	445	Btu/hr		
Glass				22.75	ft <sup>2</sup>	x	61	F	x	0.55	Btu/hr ft <sup>2</sup> F			=	763	Btu/hr		
Skylight				0.00	ft <sup>2</sup>	x	61	F	x	0.40	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr	
Roof		134	ft <sup>2</sup>	x	61	F	x	0.06	Btu/hr ft <sup>2</sup> F					=	454	Btu/hr		
Floor		0	ft <sup>2</sup>	x	61	F	x	0.03	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Infiltration		134	ft <sup>2</sup>	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	675	Btu/hr
(not treating air)												Heating		=	2,338	Btu/hr		
												Safety Factor (25%)		=	584	Btu/hr		
												MIN HEATING		=	2,922	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	30.04	Btu/lb	@	78.62	F DB	,	65.18	F WB	,	6	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	184	CFM	x	6.86	BTU/lb	x	4.5						=	5,679	Btu/hr
													Tons A/C	=	0.5	Tons
													H2O (10F delta T)	=	1	GPM
														=	283	ft2/Ton
	Mix Air T-In	66	F	@	6	% OA										
	Heat Air T-Out	87	F													
	Heating Cap	184	CFM	x	20	F	x	1.08						=	4,070	Btu/hr

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

<b>Project phase:</b>	Preliminary	<b>Project:</b>	Sturbridge Public Library			<b>Sheet</b>
<b>Trade Specification Section:</b>	15500		3 - balcony			1 of 1
<b>Date</b>						<b>Date</b>
<b>By:</b>	<b>Checked By:</b>		<b>Project No.:</b>	17123		00.00.00
<b>Design Conditions:</b>						
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>		<b>Winter</b>		
-	<b>Indoor</b>	(°F-Db/°F-Wb)	75	63	70 °F	IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb)	88	74	9 °F	

#### I. Outdoor Air Requirement

## II. Sensible Cooling Load

### **III. Heating Load**

Walls				336.09	ft <sup>2</sup>	x	61	F	x	0.08	Btu/hr ft <sup>2</sup> F			=	1,708	Btu/hr		
Glass				159.25	ft <sup>2</sup>	x	61	F	x	0.55	Btu/hr ft <sup>2</sup> F			=	5,343	Btu/hr		
Skylight				0.00	ft <sup>2</sup>	x	61	F	x	0.40	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr	
Roof		665	ft <sup>2</sup>	x	61	F	x	0.06	Btu/hr ft <sup>2</sup> F					=	2,254	Btu/hr		
Floor		0	ft <sup>2</sup>	x	61	F	x	0.03	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Infiltration		320	ft <sup>2</sup>	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	1,613	Btu/hr
(not treating air)												Heating		=	10,918	Btu/hr		
												Safety Factor (25%)		=	2,729	Btu/hr		
												MIN HEATING		=	13,647	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	30.12	Btu/lb	@	78.74	F DB	,	65.30	F WB	,	7	% OA						
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB									
	Cooling Cap	735	CFM	x	6.95	BTU/lb	x	4.5							=	22,970	Btu/hr	
														Tons A/C	=	1.9	Tons	
														H2O (10F delta T)	=	5	GPM	
															=	167	ft2/Ton	
	Mix Air T-In	65	F	@	7	% OA												
	Heat Air T-Out	89	F															
	Heating Cap	735	CFM	x	24	F	x	1.08							=	18,818	Btu/hr	

BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail [Info@blwengineers.com](mailto:Info@blwengineers.com)

## HVAC Calculations

<b>Project phase:</b>	Preliminary	<b>Project:</b>	Sturbridge Public Library			<b>Sheet</b>
<b>Trade Specification Section:</b>	15500		3 - storage			1 of 1
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b>	17123			<b>Date</b>
<b>Design Conditions:</b>						
<b>Location</b>		<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>		
-		Indoor	(°F-Db/°F-Wb) 75	63	70 °F	IMC 2012, IECC 2012
		Outdoor	(°F-Db/°F-Wb) 88	74	9 °F	

#### I. Outdoor Air Requirement

Area		137	ft <sup>2</sup>	A			Rp	P								
Ventilation	Method per Person	0.06	x	137		+										= 8.22 CFM
	per ACH	2.00 ACH	x	0	ft <sup>2</sup>	x	8.00	ft	5 x 0 / 60	min/hr					= 0 CFM	

## II. Sensible Cooling Load

Walls	N	7	ft	x	8.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	104	Btu/hr	
	S	7	ft	x	8.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	209	Btu/hr	
	E	0	ft	x	8.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	W	20	ft	x	8.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	538	Btu/hr	
	NE	0	ft	x	8.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	8.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	8.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	8.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		256	ft2	x	40.00	CLTD	x	0.06	Btu/hr ft2 F						=	569	Btu/hr	
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F						=	0	Btu/hr	
Lighting/Power		137	ft2	x	0.80	W/ft2	x	3.412	Btuh/Watt						=	374	Btu/hr	
People		0	People	x	255	Btu/hr	x	1	Diversity						=	0	Btu/hr	
Infiltration		137	ft2	x	11.25	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	147	Btu/hr
												RSH			=	1,940	Btu/hr	
												Safety Factor (15%)			=	291	Btu/hr	
												ERSH			=	2,231	Btu/hr	
												Airflow (20F delta T)			=	103	CFM	
												Sensible(w/o treating air)						

### III. Heating Load

Walls				266.13	ft <sup>2</sup>	x	61	F	x	0.08	Btu/hr ft <sup>2</sup> F			=	1,353	Btu/hr		
Glass				0.00	ft <sup>2</sup>	x	61	F	x	0.55	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Skylight				0.00	ft <sup>2</sup>	x	61	F	x	0.40	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft <sup>2</sup> F			=	0	Btu/hr	
Roof		256	ft <sup>2</sup>	x	61	F	x	0.06	Btu/hr ft <sup>2</sup> F					=	868	Btu/hr		
Floor		0	ft <sup>2</sup>	x	61	F	x	0.03	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft <sup>2</sup> F					=	0	Btu/hr		
Infiltration		137	ft <sup>2</sup>	x	11.25	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	690	Btu/hr
(not treating air)												Heating		=	2,911	Btu/hr		
												Safety Factor (25%)		=	728	Btu/hr		
												MIN HEATING		=	3,639	Btu/hr		

#### **IV. Furnace Specifications**

AHU	Enthalpy-In	30.16	Btu/lb	@	78.80	F DB	,	65.35	F WB	,	8	% OA					
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB								
	Cooling Cap	103	CFM	x	6.99	BTU/lb	x	4.5							=	3,248	Btu/hr
														Tons A/C	=	0.3	Tons
														H2O (10F delta T)	=	1	GPM
															=	506	ft2/Ton
	Mix Air T-In	65	F	@	8	% OA											
	Heat Air T-Out	105	F														
	Heating Cap	103	CFM	x	39	F	x	1.08							=	4,403	Btu/hr

## **REPLACEMENT ROOFTOP UNITS**



## SUBMITTAL

**Project**

Sturbridge Public Library

**Date**

Wednesday, July 26, 2017

# Unit Report For RTU-1

Project: Sturbridge Public Library  
Prepared By:

07/26/2017  
11:41AM

## Unit Parameters

Unit Model: **48TCFE16ACA6-0F2C0**  
Unit Size: **16 (15 Tons)**  
Volts-Phase-Hertz: **460-3-60**  
Heating Type: **Gas**  
Duct Cfg: **Vertical Supply / Vertical Return**  
High Heat  
Round Tube Plate Fin Coils

## Dimensions (ft. in.) & Weight (lb.) \*\*\*

Unit Length: **9' 7.875"**  
Unit Width: **5' 3.375"**  
Unit Height: **4' 9.375"**  
\*\*\* Total Operating Weight: **1718 lb**

\*\*\* Weights and Dimensions are approximate. Weight does not include unit packaging. Approximate dimensions are provided primarily for shipping purposes. For exact dimensions and weights, refer to appropriate product data catalog.

## Lines and Filters

Gas Line Size: **3/4**  
Condensate Drain Line Size: **3/4**  
Return Air Filter Type: **Throwaway**  
Return Air Filter Quantity: **6**  
Return Air Filter Size: **18 x 24 x 2**

## Unit Configuration

High Static Option with High Efficiency Motor (Belt Drive)  
Al/Cu - Al/Cu  
Base Electromechanical Controls  
Enthalpy Economizer w/ Barometric Relief  
Powered Convenience Outlet  
Non-Fused Disconnect  
Standard Packaging  
Humidi-MiZer™ Adaptive Dehumidification System

## Warranty Information

1-Year parts(std.)  
5-Year compressor parts(std.)  
10-Year heat exchanger - Aluminized(std.)

No optional warranties were selected.


**NOTE: Please see Warranty Catalog 500-089 for explanation of policies and ordering methods.**

## Ordering Information

Part Number	Description	Quantity
48TCFE16ACA6-0F2C0	Rooftop Unit	1
	Base Unit	
	High Static Option with High Efficiency Motor (Belt Drive)	
	Powered Convenience Outlet	
	Std leak Enty Econo IV with baro relief and W7212 control	
	Non-Fused Disconnect	

## Certified Drawing for RTU-1

07/26/2017  
11:41AM



## Certified Drawing for RTU-1

07/26/2017  
11:41AM

UNIT	STD UNIT WEIGHT	CORNER A WEIGHT (A)	CORNER B WEIGHT (B)	CORNER C WEIGHT (C)	CORNER D WEIGHT (D)	C. G.			
UNIT	LBS.	KG.	LBS.	KG.	LBS.	KG.	X	Y	Z
48 TC 16	1380	627	295	134	276	342	156	421	191




STANDARD UNIT WEIGHT IS WITH LOW HEAT & WITHOUT PACKAGING.  
FOR OPTIONS & ACCESSORIES, REFER TO THE PRODUCT DATA CATALOG.



P.O. BOX 4608  
UNITED TECHNOLOGIES TRACIUS, NY  
AND IS DELIVERED UPON THE EXPRESS CONDITION THAT THE  
CONTRACTOR WILL NOT BE DISCLOSED OR USED WITHOUT CARRIER  
CONTRACTOR'S WRITTEN CONSENT.

THIS DOCUMENT IS THE PROPERTY OF CARRIER CORPORATION  
SUBMISSION OF THESE DRAWINGS OR DOCUMENTS  
CONSTITUTES AN ACCEPTANCE OF THE CONTRACT.

CARRIER CORPORATION  
1321 CARRIER DRIVE  
MILWAUKEE, WI 53211



DATE	SUPERFICIES	48TC 16 SINGLE ZONE ELECTRICAL COOLING WITH GAS HEAT	50TMS01221	REV C
06/15/11	-			


## HORIZONTAL ECONOMIZER

# Cambridgeport

## SUBMITTAL

SUBMITTED TO \_\_\_\_\_  
COMPANY \_\_\_\_\_  
JOB NAME \_\_\_\_\_  
EQUIPMENT \_\_\_\_\_  
SIGNATURE \_\_\_\_\_  
DATE \_\_\_\_\_

Part Number  
**2010096**



### FEATURES

- ONE PIECE WELDED CONSTRUCTION
- FACTORY INSTALLED SUPPLY TRANSITIONS
- FULLY INSULATED
- DESIGNED FOR EVEN WEIGHT DISTRIBUTION
- FABRICATED OF HEAVY GAUGE G90 GALVANIZED STEEL
- ALL WELDS SPRAYED WITH GALVANIZING COMPOUND
- GASKET PROVIDED FOR UNIT TO ADAPTER SEALING

Existing Unit  
**48HJF017 (CARRIER)**


New Unit  
**48TCFD16 (CARRIER)**

CAMBRIDGEPORT STRONGLY RECOMMENDS CONFIRMING THE DIMENSIONS ON THIS SUBMITTAL

CURB ADAPTERS ARE BASED ON UNIT MANUFACTURERS STANDARD CURB DIMENSIONS.  
CAMBRIDGEPORT CANNOT BE RESPONSIBLE FOR ANY DEVIATIONS FROM FACTORY DIMENSIONS OR INCORRECT MODEL NUMBERS.

## Certified Drawing for RTU-1

07/26/2017  
11:41AM



# Performance Summary For RTU-1

Project: Sturbridge Public Library  
Prepared By:

07/26/2017  
11:41AM

## Part Number:48TCFE16ACA6-0F2C0

ARI EER:..... **10.80**  
IEER (Max Cooling at Normal Cooling Design Mode):..... **11.7**

### Base Unit Dimensions

Unit Length:..... **115.9** in  
Unit Width:..... **63.4** in  
Unit Height:..... **57.4** in

### Operating Weight

Base Unit Weight:..... **1380** lb  
High Heat:..... **50** lb  
Two Stage Compressor Models with Al/Cu condenser Coils and Humidifier:..... **90** lb  
High Static Option with High Efficiency Motor (Belt Drive):..... **45** lb  
Enthalpy Economizer w/ Barometric Relief:..... **103** lb  
Powered Convenience Outlet:..... **35** lb  
Non-Fused Disconnect:..... **.15** lb

Total Operating Weight:..... **1718** lb

### Unit

Unit Voltage-Phase-Hertz:..... **460-3-60**  
Air Discharge:..... Vertical  
Fan Drive Type:..... Belt  
Actual Airflow:..... **6000** CFM  
Site Altitude:..... **0** ft

### Cooling Performance

Condenser Entering Air DB:..... **95.0** F  
Evaporator Entering Air DB:..... **80.0** F  
Evaporator Entering Air WB:..... **67.0** F  
Entering Air Enthalpy:..... **31.44** BTU/lb  
Evaporator Leaving Air DB:..... **59.0** F  
Evaporator Leaving Air WB:..... **57.4** F  
Evaporator Leaving Air Enthalpy:..... **24.62** BTU/lb  
Gross Cooling Capacity:..... **184.10** MBH  
Gross Sensible Capacity:..... **136.00** MBH  
Compressor Power Input:..... **13.84** kW  
Coil Bypass Factor:..... **0.610**

### Heating Performance

Heating Airflow:..... **6000** CFM  
Entering Air Temp:..... **70.0** F  
Leaving Air Temp:..... **113.2** F  
Gas Heating Input Capacity:..... **280.0 / 350.0** MBH  
Gas Heating Output Capacity:..... **224.0 / 280.0** MBH  
Temperature Rise:..... **43.2** F  
Thermal Efficiency (%):..... **80.0**

### Supply Fan

External Static Pressure:..... **1.00** in wg  
Options / Accessories Static Pressure  
    Humidi-MiZer Dehumidification System:..... **0.11** in wg  
    Economizer:..... **0.05** in wg  
Total Application Static (ESP + Unit Opts/Acc.):..... **1.16** in wg  
Fan RPM:..... **832**  
Fan Power:..... **3.86** BHP  
NOTE:..... **Selected IFM RPM Range: 776 - 955**

### Electrical Data

# Performance Summary For RTU-1

Project: Sturbridge Public Library  
Prepared By:

07/26/2017  
11:41AM

Voltage Range:	414 - 506
Compressor #1 RLA:	12.2
Compressor #1 LRA:	100
Compressor #2 RLA:	12.8
Compressor #2 LRA:	100
Indoor Fan Motor Type:	High Eff. High
Indoor Fan Motor FLA:	10.2
Combustion Fan Motor FLA (ea):	0.25
Power Supply MCA:	43
Power Supply MOCP (Fuse or HACR):	50
Disconnect Size FLA:	46
Disconnect Size LRA:	254
Electrical Convenience Outlet FLA (based on unit line voltage):	2.2
Outdoor Fan [Qty / FLA (ea)]:	3 / 0.8

NOTE: Convenience outlet must be field connected to the line/load side of the unit disconnect per local code.


## Control Panel SCCR: 5kA RMS at Rated Symmetrical Voltage

### Acoustics

Sound Power Levels, db re 10E-12 Watts

	Discharge	Inlet	Outdoor
63 Hz	96.9	93.4	87.0
125 Hz	97.4	88.3	85.2
250 Hz	83.5	69.3	84.6
500 Hz	79.4	68.8	84.9
1000 Hz	74.8	67.3	82.2
2000 Hz	70.3	64.1	78.4
4000 Hz	76.3	65.2	75.3
8000 Hz	76.0	61.8	72.9
A-Weighted	85.4	76.1	87.0

### Advanced Acoustics



#### Advanced Acoustics Parameters

1. Unit height above ground:..... 30.0 ft
2. Horizontal distance from unit to receiver:..... 50.0 ft
3. Receiver height above ground:..... 5.7 ft
4. Height of obstruction:..... 0.0 ft
5. Horizontal distance from obstruction to receiver:..... 0.0 ft
6. Horizontal distance from unit to obstruction:..... 0.0 ft

### Detailed Acoustics Information

# Performance Summary For RTU-1

Project: Sturbridge Public Library  
Prepared By:

07/26/2017  
11:41AM

Octave Band Center Freq. Hz	63	125	250	500	1k	2k	4k	8k	Overall
A	87.0	85.2	84.6	84.9	82.2	78.4	75.3	72.9	92.4 Lw
B	60.8	69.1	76.0	81.7	82.2	79.6	76.3	71.8	87.1 LwA
C	54.6	52.8	52.2	52.5	49.8	46.0	42.9	40.5	60.0 Lp
D	28.4	36.7	43.6	49.3	49.8	47.2	43.9	39.4	54.7 LpA

## Legend


A Sound Power Levels at Unit's Acoustic Center, Lw

B A-Weighted Sound Power Levels at Unit's Acoustic Center, LwA

C Sound Pressure Levels at Specific Distance from Unit, Lp

D A-Weighted Sound Pressure Levels at Specific Distance from Unit, LpA

Calculation methods used in this program are patterned after the ASHRAE Guide; other ASHRAE Publications and the AHRI Acoustical Standards. While a very significant effort has been made to insure the technical accuracy of this program, it is assumed that the user is knowledgeable in the art of system sound estimation and is aware of the tolerances involved in real world acoustical estimation. This program makes certain assumptions as to the dominant sound sources and sound paths which may not always be appropriate to the real system being estimated. Because of this, no assurances can be offered that this software will always generate an accurate sound prediction from user supplied input data. If in doubt about the estimation of expected sound levels in a space, an Acoustical Engineer or a person with sound prediction expertise should be consulted.



# Unit Report For RTU-2

Project: Sturbridge Public Library  
Prepared By:

07/26/2017  
11:41AM

## Unit Parameters

Unit Model: **48TCFE08A2A6-0F2C0**  
Unit Size: **08 (7.5 Tons)**  
Volts-Phase-Hertz: **460-3-60**  
Heating Type: **Gas**  
Duct Cfg: **Vertical Supply / Vertical Return**  
High Heat  
Round Tube Plate Fin Coils

## Dimensions (ft. in.) & Weight (lb.) \*\*\*

Unit Length: **7' 4.125"**  
Unit Width: **4' 11.5"**  
Unit Height: **3' 5.25"**  
\*\*\* Total Operating Weight: **1083 lb**

\*\*\* Weights and Dimensions are approximate. Weight does not include unit packaging. Approximate dimensions are provided primarily for shipping purposes. For exact dimensions and weights, refer to appropriate product data catalog.

## Lines and Filters

Gas Line Size: **3/4**  
Condensate Drain Line Size: **3/4**  
Return Air Filter Type: **Throwaway**  
Return Air Filter Quantity: **4**  
Return Air Filter Size: **16 x 20 x 2**

## Unit Configuration

Medium Static Option (Belt Drive)  
Al/Cu - Al/Cu  
Base Electromechanical Controls  
Enthalpy Economizer w/ Barometric Relief  
Powered Convenience Outlet  
Non-Fused Disconnect  
Standard Packaging  
Humidi-MiZer™ Adaptive Dehumidification System

## Warranty Information

1-Year parts(std.)  
5-Year compressor parts(std.)  
10-Year heat exchanger - Aluminized(std.)

No optional warranties were selected.


**NOTE: Please see Warranty Catalog 500-089 for explanation of policies and ordering methods.**

## Ordering Information

Part Number	Description	Quantity
48TCFE08A2A6-0F2C0	Rooftop Unit	1
	Base Unit	
	Medium Static Option (Belt Drive)	
	Powered Convenience Outlet	
	Std leak Enty Econo IV with baro relief and W7212 control	
	Non-Fused Disconnect	

## Certified Drawing for RTU-2


07/26/2017  
11:41AM



## Certified Drawing for RTU-2

07/26/2017  
11:41AM


UNIT	OUTDOOR COIL TYPE	STD. UNIT WEIGHT ***	CORNER A WEIGHT (A)	CORNER B WEIGHT (B)	CORNER C WEIGHT (C)	CORNER D WEIGHT (D)	C.G.
48IC-A08	RIPF	780	354	178	81	158	72
48IC-A09	RIPF	920	418	196	83	212	96
48IC-A12	RIPF	930	422	216	98	196	89
48IC-D08	RIPF	835	319	164	74.5	170	77.2
48IC-D09	RIPF	930	422	228	103.5	187	85
48IC-D12	RIPF	940	447	231	164.9	189	85.8
48IC-D08	WCHX	805	365.5	160	12.6	153	69.5
48IC-D12	WCHX	805	406.3	185	84	176	79.9
RIPF - ROUND TUBE PLATE FIN (COPPER/ALUM) MCIX - NOVATION (ALUM/ALUM)							



SHEET	DATE	SUPERFACES	48TC 08-12 SINGLE ZONE ELECTRICAL	REV
2 OF 2	03-08-10	11-24-08	48TM500985	F

## Certified Drawing for RTU-2


07/26/2017  
11:41AM



## Certified Drawing for RTU-2

07/26/2017  
11:41AM


UNIT	OUTDOOR COIL TYPE	STD. UNIT WEIGHT ***	CORNER A WEIGHT (A)	CORNER B WEIGHT (B)	CORNER C WEIGHT (C)	CORNER D WEIGHT (D)	C.G.
48IC-A08	RIPF	780	354	178	81	158	72
48IC-A09	RIPF	920	418	196	83	212	96
48IC-A12	RIPF	930	422	216	98	196	89
48IC-D08	RIPF	835	319	164	74.5	170	77.2
48IC-D09	RIPF	930	422	228	103.5	187	85
48IC-D12	RIPF	940	447	231	164.9	189	85.8
48IC-D08	WCHX	805	365.5	160	12.6	153	69.5
48IC-D12	WCHX	805	406.3	185	84	176	79.9
RIPF - ROUND TUBE PLATE FIN (COPPER/ALUM) MCIX - NOVATION (ALUM/ALUM)							



SHEET	DATE	SUPERFACES	48TC 08-12 SINGLE ZONE ELECTRICAL	REV
2 OF 2	03-08-10	11-24-08	48TM500985	F


## Certified Drawing for RTU-2

07/26/2017  
11:41AM



## Certified Drawing for RTU-2

07/26/2017  
11:41AM



## Performance Summary For RTU-2

Project: Sturbridge Public Library  
Prepared By:

07/26/2017  
11:41AM

### Part Number:48TCFE08A2A6-0F2C0

ARI EER:..... **11.00**  
IEER (Max Cooling at Normal Cooling Design Mode):..... **11.7**

#### Base Unit Dimensions

Unit Length:..... **88.1** in  
Unit Width:..... **59.5** in  
Unit Height:..... **41.3** in

#### Operating Weight

Base Unit Weight:..... **835** lb  
High Heat:..... **29** lb  
Two Stage Compressor Models with Al/Cu condenser Coils and Humidifier:..... **80** lb  
Medium Static Option (Belt Drive):..... **15** lb  
Enthalpy Economizer w/ Barometric Relief:..... **74** lb  
Powered Convenience Outlet:..... **35** lb  
Non-Fused Disconnect:..... **.15** lb

Total Operating Weight:..... **1083** lb

#### Unit

Unit Voltage-Phase-Hertz:..... **460-3-60**  
Air Discharge:..... Vertical  
Fan Drive Type:..... Belt  
Actual Airflow:..... **3000** CFM  
Site Altitude:..... **0** ft

#### Cooling Performance

Condenser Entering Air DB:..... **95.0** F  
Evaporator Entering Air DB:..... **80.0** F  
Evaporator Entering Air WB:..... **67.0** F  
Entering Air Enthalpy:..... **31.44** BTU/lb  
Evaporator Leaving Air DB:..... **59.8** F  
Evaporator Leaving Air WB:..... **57.8** F  
Evaporator Leaving Air Enthalpy:..... **24.90** BTU/lb  
Gross Cooling Capacity:..... **88.30** MBH  
Gross Sensible Capacity:..... **65.30** MBH  
Compressor Power Input:..... **6.12** kW  
Coil Bypass Factor:..... **0.070**

#### Heating Performance

Heating Airflow:..... **3000** CFM  
Entering Air Temp:..... **70.0** F  
Leaving Air Temp:..... **126.8** F  
Gas Heating Input Capacity:..... **180.0 / 224.0** MBH  
Gas Heating Output Capacity:..... **147.0 / 184.0** MBH  
Temperature Rise:..... **56.8** F  
Thermal Efficiency (%):..... **82.0**

#### Supply Fan

External Static Pressure:..... **1.00** in wg  
Options / Accessories Static Pressure  
    Humidi-MiZer Dehumidification System:..... **0.18** in wg  
    Economizer:..... **0.11** in wg  
Total Application Static (ESP + Unit Opts/Acc.):..... **1.29** in wg  
Fan RPM:..... **941**  
Fan Power:..... **2.78** BHP  
NOTE:..... **Selected IFM RPM Range: 733 - 949**

#### Electrical Data

## Performance Summary For RTU-2

Project: Sturbridge Public Library  
Prepared By:

07/26/2017  
11:41AM

Voltage Range:	<b>414 - 506</b>
Compressor #1 RLA:	<b>6.1</b>
Compressor #1 LRA:	<b>41</b>
Compressor #2 RLA:	<b>6.1</b>
Compressor #2 LRA:	<b>41</b>
Indoor Fan Motor Type:	<b>MED</b>
Indoor Fan Motor FLA:	<b>4.2</b>
Combustion Fan Motor FLA (ea):	<b>0.25</b>
Power Supply MCA:	<b>22</b>
Power Supply MOCP (Fuse or HACR):	<b>25</b>
Disconnect Size FLA:	<b>23</b>
Disconnect Size LRA:	<b>124</b>
Electrical Convenience Outlet FLA (based on unit line voltage):	<b>2.2</b>
Outdoor Fan [Qty / FLA (ea)]:	<b>2 / 0.8</b>

NOTE: Convenience outlet must be field connected to the line/load side of the unit disconnect per local code.


### Control Panel SCCR: 5kA RMS at Rated Symmetrical Voltage

#### Acoustics

Sound Power Levels, db re 10E-12 Watts

	<b>Discharge</b>	<b>Inlet</b>	<b>Outdoor</b>
63 Hz	99.7	97.1	85.8
125 Hz	92.8	88.8	84.3
250 Hz	81.0	78.3	80.5
500 Hz	73.0	69.2	78.7
1000 Hz	70.8	66.8	76.4
2000 Hz	69.9	61.8	72.7
4000 Hz	70.7	61.6	68.3
8000 Hz	75.0	60.6	65.1
A-Weighted	82.0	77.3	82.0

#### Advanced Acoustics



#### Advanced Acoustics Parameters

1. Unit height above ground:..... **30.0** ft
2. Horizontal distance from unit to receiver:..... **50.0** ft
3. Receiver height above ground:..... **5.7** ft
4. Height of obstruction:..... **0.0** ft
5. Horizontal distance from obstruction to receiver:..... **0.0** ft
6. Horizontal distance from unit to obstruction:..... **0.0** ft

#### Detailed Acoustics Information

## Performance Summary For RTU-2

Project: Sturbridge Public Library  
Prepared By:

07/26/2017  
11:41AM

Octave Band Center Freq. Hz	63	125	250	500	1k	2k	4k	8k	Overall
A	85.8	84.3	80.5	78.7	76.4	72.7	68.3	65.1	89.6 Lw
B	59.6	68.2	71.9	75.5	76.4	73.9	69.3	64.0	81.4 LwA
C	53.4	51.9	48.1	46.3	44.0	40.3	35.9	32.7	57.2 Lp
D	27.2	35.8	39.5	43.1	44.0	41.5	36.9	31.6	49.0 LpA

### Legend

A Sound Power Levels at Unit's Acoustic Center, Lw

B A-Weighted Sound Power Levels at Unit's Acoustic Center, LwA

C Sound Pressure Levels at Specific Distance from Unit, Lp

D A-Weighted Sound Pressure Levels at Specific Distance from Unit, LpA

Calculation methods used in this program are patterned after the ASHRAE Guide; other ASHRAE Publications and the AHRI Acoustical Standards. While a very significant effort has been made to insure the technical accuracy of this program, it is assumed that the user is knowledgeable in the art of system sound estimation and is aware of the tolerances involved in real world acoustical estimation. This program makes certain assumptions as to the dominant sound sources and sound paths which may not always be appropriate to the real system being estimated. Because of this, no assurances can be offered that this software will always generate an accurate sound prediction from user supplied input data. If in doubt about the estimation of expected sound levels in a space, an Acoustical Engineer or a person with sound prediction expertise should be consulted.

