

January 17, 2024

Zoning Board of Appeals
Town of Sturbridge
301 Main Street
Sturbridge, MA 01566

**RE: Special Permit Application
Stephen and Rebecca Celuzza
125 Mashapaug Road, Sturbridge, MA 01566**

Dear Board Members:

McClure Engineering, Inc. (McClure) on behalf of Stephen and Rebecca Celuzza submits this septic certification letter as required by Section 18:04 (i) of the Special Permit Application. The application is for an accessory dwelling which will be attached to the existing house. The existing septic design was for a four (4) bedroom (440 gal/day) but the design flow was for a 6 bedroom (660 gal/day) septic system. The proposed addition will add one bedroom to the system for a total of 5 bedrooms(550 gal/day). This system has sufficient design capacity for the proposed addition.

Please contact McClure at 508.248.2005 with any further comments or questions relating to the issuance of this letter.

Sincerely,



Robert P. Duff, P.E.
Senior Engineer

cc: Stephen & Rebecca Celuzza, 125 Mashapaug Road, Sturbridge, MA 01566